



IEC SYSTEM FOR CONFORMITY
TESTING TO STANDARDS FOR
SAFETY OF ELECTRICAL
EQUIPMENT (IECEE) CB SCHEME

Ref. Certificate No.

HU-370

CB TEST CERTIFICATE

Issued by: Hungarian Institute for Testing and Certification of Electrical Equipment Ltd. (MEEI Ltd.)

Registration date: 2005-05-11

Product: Flush-type double socket-outlets with side- or pin-type earthing contacts

Applicant: Legrand Magyarország Ipartelepi út 14 Hungary
Villamossági 6600 Szentes
Rendszerek Rt.

Manufacturer: Legrand Magyarország Ipartelepi út 14 Hungary
Villamossági 6600 Szentes
Rendszerek Rt.

Factory: Legrand Magyarország Ipartelepi út 14 Hungary
Villamossági 6600 Szentes
Rendszerek Rt.

Rating and principal characteristics: 16A 250V AC, IP20
flush-type, rewirable, with earthing contact, screw-type terminals

Trade mark (if any): Legrand

Model/Type reference: BMD 040, BMD 050, BMD 060

Additional information:

Sample of product tested to be in conformity with IEC: 60884-1(ed.3) IEC 60083:1975 St. Sh. C2a
(CEE 7 St. Sh. III)
IEC 60083:1975 St. Sh. C3a
(CEE 7 St. Sh. V)

Test Report Ref. No: V-15760

This CB Test Certificate is issued by the National Certification Body

Hungarian Institute for Testing and Certification of Electrical Equipment Ltd. (MEEI Ltd.)
Váci út 48/a-b, 1132 Budapest, Hungary

Signed by: Lajos LAZUR, Managing Director

Date of issue: 2005-05-11

