

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Plugs, socket-outlets and couplers for industrial purposes

Name and address of the applicant

LEGRAND FRANCE
6, Paul Nouel
76770 MALAUNAY
FRANCE

Name and address of the manufacturer

LEGRAND FRANCE
6, Paul Nouel
76770 MALAUNAY
FRANCE

Name and address of the factory

See Annex

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

16 A and 32 A
See Annex

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

CTF2

Model / Type Ref.

Series: P17 Tempra Pro
References: See Annex

Additional information (if necessary may also be reported on page 2)

 Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60309-1:1999(ed. 4) +A1:2005 +A2:2012,
IEC 60309-2:1999(ed. 4) +A1:2005 +A2:2012

As shown in the Test Report Ref. No. which forms part of this Certificate

60011202-503723A to 60011202-503723A/4,
60011202-503723B to 60011202-503723B/4,
150665-709651

This CB Test Certificate is issued by the National Certification Body

LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.frLABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15745000 €
RCS Nanterre 8408863174
33 Avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Date: 27/12/2017

Signature: **Jean-François BRUEL**
Certification Officer

ANNEX

Name and address of the factories:**LEGRAND FRANCE**

670 route de Tendos
76690 FONTAINE LE BOURG
FRANCE

LEGRAND MAGYARORSZAG VILLAMOSSAGI RENDSZEREK ZRT

Ipartelepi ut 14 pf 10
6600 SZENTES
HUNGARY

References, ratings and main characteristics:


| Connector | | | | | | References |
|-----------|-----------------|----------|-----------|-------------------|----------|------------|
| Current | Number of poles | Voltage | Frequency | Earthing position | Material | IP 44 |
| 16A | 2P | 20/25 V~ | 50/60Hz | / | Plastic | 0 552 31 |
| 16A | 2P | 40/50 V~ | 50/60Hz | 12h* | Plastic | 0 552 33 |
| 16A | 3P | 40/50 V~ | 50/60Hz | 12h* | Plastic | 0 552 34 |
| 32A | 2P | 20/25 V~ | 50/60Hz | / | Plastic | 0 552 81 |

*Keyway position

| Bending plug | | | | | | References | |
|--------------|-----------------|--------------------------------|-----------|-------------------|----------|------------|----------|
| Current | Number of poles | Voltage | Frequency | Earthing position | Material | IP 44 | IP 66/67 |
| 16A | 2P+E | 200/250 V~ | 50/60Hz | 6h | Plastic | 0 564 53 | 0 565 03 |
| 16A | 3P+E | 380/415 V~ | 50/60Hz | 6h | Plastic | 0 564 57 | 0 565 07 |
| 16A | 3P+N+E | 200/346 V~ to 240/415 V~ | 50/60Hz | 6h | Plastic | 0 564 58 | 0 565 08 |
| 32A | 2P+E | 200/250 V~ | 50/60Hz | 6h | Plastic | 0 564 73 | 0 565 23 |
| 32A | 3P+E | 380/415 V~ | 50/60Hz | 6h | Plastic | 0 564 77 | |
| 32A | 3P+N+E | 200/346 V~ to 240/415 V~ | 50/60Hz | 6h | Plastic | 0 56478 | 0 565 28 |



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



Date: 27/12/2017

Signature: **Jean-François BRUEL**
Certification Officer

ANNEX (cont'd)

| Appliance inlet | | | | | | References | |
|-----------------|-----------------|--------------------------------|-----------|-------------------|----------|------------|----------|
| Current | Number of poles | Voltage | Frequency | Earthing position | Material | IP 44 | IP 66/67 |
| 16A | 2P | 20/25 V~ | 50/60Hz | / | Plastic | 0 552 41 | |
| 16A | 3P | 40/50 V~ | 50/60Hz | 12h* | Plastic | 0 552 44 | |
| 16A | 2P+E | 100/130 V~ | 50/60Hz | 4h | Plastic | 0 575 81 | |
| 16A | 2P+E | 200/250 V~ | 50/60Hz | 6h | Plastic | 0 575 84 | 0 568 03 |
| 16A | 3P+E | 200/250 V~ | 50/60Hz | 9h | Plastic | 0 575 85 | |
| 16A | 3P+N+E | 120/208 V~ to 144/250 V~ | 50/60Hz | 9h | Plastic | 0 575 86 | |
| 16A | 3P+N+E | 200/346 V~ to 240/415 V~ | 50/60Hz | 6h | Plastic | 0 575 89 | 0 568 08 |
| 16A | 3P+E | 380/415 V~ | 50/60Hz | 6h | Plastic | 0 575 88 | 0 568 07 |
| 32A | 2P | 20/25 V~ | 50/60Hz | / | Plastic | 0 552 91 | |
| 32A | 2P+E | 100/130 V~ | 50/60Hz | 4h | Plastic | 0 582 81 | |
| 32A | 2P+E | 200/250 V~ | 50/60Hz | 6h | Plastic | 0 582 84 | 0 568 23 |
| 32A | 3P+E | 380/415 V~ | 50/60Hz | 6h | Plastic | 0 582 88 | 0 568 27 |
| 32A | 3P+N+E | 120/208 V~ to 144/250 V~ | 50/60Hz | 6h | Plastic | 0 582 86 | |
| 32A | 3P+N+E | 200/346 V~ to 240/415 V~ | 50/60Hz | 6h | Plastic | 0 582 89 | 0 568 28 |


*Keyway position

| Surface Socket | | | | | | References |
|----------------|-----------------|-------------------------------|-----------|-------------------|----------|------------|
| Current | Number of poles | Voltage | Frequency | Earthing position | Material | IP 44 |
| 16A | 2P | 20 to 25V DC 40 to 50 V DC | / | 10h* | Plastic | 0 552 10 |
| 16A | 2P | 20/25 V~ | 50/60Hz | / | Plastic | 0 552 06 |
| 16A | 3P | 20/25 V~ | 50/60Hz | / | Plastic | 0 552 07 |
| 16A | 2P | 40/50 V~ | 50/60Hz | 12h* | Plastic | 0 552 08 |
| 16A | 3P | 40/50 V~ | 50/60Hz | 12h* | Plastic | 0 552 09 |
| 32A | 2P | 20/25 V~ | 50/60Hz | / | Plastic | 0 552 56 |
| 32A | 3P | 40/50 V~ | 50/60Hz | 12h* | Plastic | 0 552 59 |
| 32A | 2P | 40/50 V~ | 50/60Hz | 12h* | Plastic | 0 552 58 |

*Keyway position



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



Date: 27/12/2017

Signature: **Jean-François BRUEL**
Certification Officer


ANNEX (cont'd)

| Straight Plug | | | | | | References |
|---------------|-----------------|-------------------------------|-----------|-------------------|----------|------------|
| Current | Number of poles | Voltage | Frequency | Earthing position | Material | IP 44 |
| 16A | 2P | 20/25 V~ | 50/60Hz | / | Plastic | 0 552 21 |
| 16A | 3P | 20/25 V~ | 50/60Hz | / | Plastic | 0 552 22 |
| 16A | 2P | 20 to 25V DC 40 to 50 V DC | / | 10h* | Plastic | 0 552 25 |
| 16A | 2P | 40/50 V~ | 50/60Hz | 12h* | Plastic | 0 552 23 |
| 16A | 3P | 40/50 V~ | 50/60Hz | 12h* | Plastic | 0 552 24 |
| 32A | 2P | 20/25 V~ | 50/60Hz | / | Plastic | 0 552 71 |
| 32A | 2P | 20 to 25V DC 40 to 50 V DC | / | 10h* | Plastic | 0 552 75 |
| 32A | 2P | 40/50 V~ | 50/60Hz | 12h* | Plastic | 0 552 73 |
| 32A | 3P | 40/50 V~ | 50/60Hz | 12h* | Plastic | 0 552 74 |

*Keyway position



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



Date: 27/12/2017

Signature: **Jean-François BRUEL**
Certification Officer


ANNEX (end)

| Panel Socket | | | | | References | |
|--------------|-----------------|--------------------------------|-----------|-------------------|------------|----------------------|
| Current | Number of poles | Voltage | Frequency | Earthing position | Material | IP 44 |
| 16A | 2P | 20/25 V~ | 50/60Hz | / | Plastic | 0 552 45 0 552 11 |
| 16A | 2P | 20 to 25V DC 40 to 50 V DC | / | 10h* | Plastic | 0 573 50 0 552 15 |
| 16A | 2P | 40/50 V~ | 50/60Hz | 12h* | Plastic | 0 552 47 |
| 16A | 3P | 40/50 V~ | 50/60Hz | 12h* | Plastic | 0 552 48 |
| 16A | 2P+E | 100/130 V~ | 50/60Hz | 4h | Plastic | 0 573 51 |
| 16A | 2P+E | 200/250 V~ | 50/60Hz | 6h | Plastic | 0 573 54 |
| 16A | 3P+N+E | 200/346 V~ to 240/415 V~ | 50/60Hz | 6h | Plastic | 0 573 59 |
| 16A | 3P+E | 380/415 V~ | 50/60Hz | 6h | Plastic | 0 573 58 |
| 32A | 2P | 20/25 V~ | 50/60Hz | / | Plastic | 0 552 95 |
| 32A | 2P | 20 to 25V DC 40 to 50 V DC | / | 10h* | Plastic | 0 552 65 |
| 32A | 2P | 40/50 V~ | 50/60Hz | 12h* | Plastic | 0 552 97 |
| 32A | 3P | 40/50 V~ | 50/60Hz | 12h* | Plastic | 0 552 64 |
| 32A | 2P+E | 200/250 V~ | 50/60Hz | 6h | Plastic | 0 580 54 |
| 32A | 3P+N+E | 200/346 V~ to 240/415 V~ | 50/60Hz | 6h | Plastic | 0 580 59 |
| 32A | 3P+E | 380/415 V~ | 50/60Hz | 6h | Plastic | 0 580 58 |

*Keyway position



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



Date: 27/12/2017

Signature: **Jean-François BRUEL**
Certification Officer