

CERTIFICATE

KEMA No.: **99.6433.07**

Issued to:

Applicant:

**Legrand Osterreich GmbH
Industriestraße 4
9241 WERNBERG, Austria**

Manufacturer/Licensee:

**Legrand Osterreich GmbH
Industriestraße 4
9241 WERNBERG, Austria**

Product : enclosures

Trade name : LEGRAND

Types/models : 7761.1, 7761.2, 7761.3

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

KEMA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60669-1:1995
- an inspection of the production location according tot CCA Group Operational Document CCA 204
- a certification agreement with the number 901244.

KEMA hereby grants the right to use the KEMA certification mark



The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: April 7, 2000

C.M. Boschloo
Certification Manager

© Integral publication of this certificate is allowed



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

product : enclosures
trade name : LEGRAND
types : 7761.1, 7761.2, 7761.3
method of mounting : surface type
description : housing of thermoplastic material
markings : - tradename and series-indication are shown on the housing

Additional information

The housing shall be used in combination with different versions of sealing slides for cables or tubes.

The housings are intended for installation of flush-type switches and socket outlets.

The digits in the type reference indicating the colours.

Product data - type 7761.1

design : singular version

Product data - type 7761.2

design : two-fold

Product data - type 7761.3

design : three-fold

TESTS**Test requirements**

- NEN 1020, 4th. edition: 1987 (based on IEC 60884-1)
- EN 60669-1: 1995.

Test result

The test results are laid down in KEMA test file 99.6433.07.

Conclusion

The examination proved that all test requirements were met.

Tested by : H. Boers 

Checked by : H.R.M. Barends 

KEMA Registered Quality B.V.

Utrechtseweg 310, 6812 AR Arnhem, The Netherlands
P.O. Box 9035, 6800 ET Arnhem, The Netherlands
Telephone +31 26 3 56 28 50, Telefax +31 26 3 51 49 22

Factory-Location

Legrand Osterreich GmbH,
Industriestraße 4, 9241 Wernberg, Austria