

CERTIFICATE

Issued to:
Applicant:
Legrand France
128, av. du Maréchal-de-Lattre
87045 Limoges Cedex, France

Manufacturer/Licensee:
Legrand France
128, av. du Maréchal-de-Lattre
87045 Limoges Cedex, France

Product(s) : socket-outlets (2-pole)
Trade name(s) : LEGRAND
Type(s)/model(s) : 7824x1, 7824x2, 7824x3, 7824x8, 7824x0, 7824y0, 7824y3

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard IEC 60884-1:2002 + A1: 2006, NEN 1020:1987 + A2: 2004
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 900095

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.


This certificate is issued on: 12 November 2012 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 2158021.01

DEKRA Certification B.V.



drs. G.J. Zoetbrood
Managing Director



H.L. Schendstok
Certification Manager

© Integral publication of this certificate is allowed

All testing, inspection, auditing and certification activities of the former KEMA Quality are an integral part of the DEKRA Certification Group.

ACCREDITED BY
THE DUTCH COUNCIL
FOR ACCREDITATION



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

product	:	socket-outlets (2-pole)
trade name	:	LEGRAND
types	:	7824x1, 7824x2, 7824x3, 7824x8, 7824x0, 7824y0, 7824y3
method of mounting	:	surface type
cover	:	cover of thermoplasticmaterial
terminals	:	screw terminals
rated current	:	16 A
rated voltage	:	250 V~
markings	:	-tradename, series indication and electrical ratings on the socket-outlet

Additional information

the x and y in the type reference will be replaced by a number

as follows:

x=1: white
x=4: ivor
x=7: wood
y=2: white
y=5: ivor
y=8: wood

Product data - type 7824x1

earthing	:	with side earthing-contacts
design	:	singular type

Product data - type 7824x2

earthing	:	without earthing contact
design	:	two-fold

Product data - type 7824x3

earthing	:	with side earthing-contacts
design	:	two-fold

Product data - type 7824x8

earthing	:	with side earthing-contacts
design	:	three-fold, safety socket-outlet

Product data - type 7824x0

earthing	:	without earthing contact
design	:	singular type

Product data - type 7824y0

earthing : with side earthing contacts
design : singular type, safety socket-outlet

Product data - type 7824y3

earthing : with side earthing-contacts
design : two-fold, safety socket-outlet
uitvoering : 2-VOUDIG

TESTS**Test requirements**

IEC 60884-1:2002 + A1:2006
NEN 1020:1987 + A2:2004

Test result

The test results are laid down in DEKRA test file 2158021.01.

Remarks


This certificate is also based on the LCIE CB Test Certificate FR-625937B.

Conclusion

The examination proved that all test requirements were met.

Tested by : LCIE

Checked by : H.R.M. Barends

**Factory locations**

Mio Conto Kft
Elege 72-76, 6630, Mintszent
Hungary