

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product	Surge protective devices
Name and address of the applicant	LEGRAND FRANCE SA 128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY 87045 LIMOGES CEDEX France
Name and address of the manufacturer	Phoenix Contact GmbH & Co. KG Flachsmarktstrasse 8, 32825 Blomberg Germany
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 Phoenix Contact GmbH & Co. KG Flachsmarktstrasse 8, 32825 Blomberg Germany
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	Uc 440 Vac, Up 2,5 kV, In 35 kA, Iimp 35 kA
Trademark (if any)	LEGRAND
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	412280, 412286
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 61643-11:2011
As shown in the Test Report Ref. No. which forms part of this Certificate	2197939.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands

